

Page No.	Clause	Condition	Query Abstract	Clarifications
17	3.2 A	Consortium	1) How many members can constitute a consortium? Is there a maximum cap?	Consortium not exceeding 3 partners. Prime bidder with two partners.
24	3.6 (2)	Consortium	2) If a foreign company is part of the consortium what are the requirements for company formation if the consortium is selected as successful bidder	Conditions as specified in RfP document clause 3.2 A (II) & (III) are confirmed
19	3.2 B (5)	Net worth of foreign firm	3)What are the documents that need to be submitted for establishing the financial credentials for the foreign firm for net worth/turnover eligibility	Net worth Certificate duly signed by the Indian Chartered Accountant and the annual report including the audited balance sheet, profit & loss accounts for the financial years 2014-15,2015-16 & 2016-17 shall have to be submitted.
23	3.5		4) Is there a minimum stake holding for any member of the consortium? Can the member have zero stake-holding? (Ex. One of the members is providing technical qualification only to the consortium)	The percentage of minimum shareholding shall be indicated as specified in clause (5) of format 5.5 of RfP.
34	4.6.1	Shortlisting of Bidder	Selection of bidders to be based on rate offered to the developers. There is no rate format provided in the RfP doc.	Shortlisting of bidders will be done based on the factors specified in clause 4.6.1. of RfP.
18	3.2 B (1)	This clause must	As per the bid, the bidder is required to	Conditions as specified in RfP document clause

		remove	demonstrate 10% of the land its own name and an authorization for the remaining 90%. This is an added cost and burden on the bidder as without being selected at least to the RFP it is impossible for any bidder to demonstrate this.	3.2 B are confirmed.
19	3.2 B (3)		<p>Can we divide the 500MW to two locations i.e., 250MW at each location (1250 acres)?</p> <p>If yes, then can we connect each location to a different sub-station, as it is unlikely to obtain evacuation clearance from TANGEDCO of 500MW at a single SS</p>	Yes. As per MNRE latest instruction, setting up of 500 MW solar park in Tamil Nadu at two locations in close vicinity each measuring 1250 acres is acceptable. However, the entire capacity of 500 MW may be treated as a single solar park and to be developed by only one Solar Power Park Developer (SPPD). The evacuation is from single 400 KV Sub-station only.
22	3.4.2 (4)		Can we change the land post the EOI stage?	EOI is to know the credential of the interested parties. However, the details to be provided in the RfP will only be considered for shortlisting of bidders.
			Should we specify the SS details at the time of applying for the EOI?	EOI process had already completed. The details to be provided in the RfP will only be considered for evaluation.

			<p>What if evacuation is rejected by TANGEDCO after being shortlisted by TEDA? Arranging 2500 acres at another location is impossible. What are the next steps then? Will the bidder be eligible for getting the EMD back?</p>	<p>EMD will be refunded.</p>
9	1.4		<p>Is connection possible to CTU? If so, can separate evacuation be done just for 20% (whatever is required for state DISCOM offtake) to STU, and the remaining to CTU? If answer to both questions is yes, then, can there be a lower voltage level of connection for STU (instead of just 400kV).</p>	<p>Conditions as specified in RfP document clause 1.4 and as per the scheme guidelines issued by MNRE are confirmed.</p>